

15A-4-205 Amendments to IRC applicable to City of North Salt Lake.

The following amendment is adopted as an amendment to the IRC for the City of North Salt Lake, a new IRC, Section R324, is added as follows: "Section R324 Automatic Sprinkler System Requirements. R324.1 When Required. An automatic sprinkler system shall be installed throughout every dwelling when the following condition is present:

1. The structure is over 6,200 square feet.

R324.2 Installation requirements and standards. Such sprinkler system shall be installed in basements, but need not be installed in garages, under eaves, or in enclosed attic spaces, unless required by the fire chief. Such system shall be installed in accordance with NFPA 13D."

Enacted by Chapter 14, 2011 General Session